CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING – BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

CATEGORY: Control Unit (High-Rise)

LISTEE: Honeywell International, Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Model XLS140-2 fire alarm control unit. Local, auxiliary, remote station (PPU), proprietary
(PPU), central station (PPU), manual, automatic, waterflow and sprinkler supervisory
services. Also suitable for releasing service. Model numbers may be followed by a "R"
suffix representing the enclosure color being red. Refer to listee's data sheet for additional
detailed product description and operational considerations. System components:

XLS140-2	CPU Board
XLS-NCA-2	Network Communication Annunciator
NCM-W, -F	Network Control Module
LEM-320/XLS-ELEM-320	Loop Expander Module
KDM-R2	Keyboard Display Module
TM-4	Transmitter Module
KAPS-24	Power Supply
CAB-4 Series	Enclosure
DP-1B	Blank Panel
BMP-1	Blank Module
ADP-4B, -A4, -1, -2, DP-DISP2	Dress Panels
CA-1, CA-2, CHS2-M2	Chassis
BB-100, -200, XLS-LBB/-LBBR	Battery Boxes
XLS-BP2-4	Battery Dress Plates
ACM-16AT, -32A, -24AT, -48A	Annunciator Control Modules
AEM-16AT, -32A, -24AT, -48A	Annunciator Expander Modules
AFM-16A, -16AT, -32A	Annunciator Fixed Modules
XLS-AKS-1B	Annunciator Key Switch
RPT-W, -485W	Repeater Wire
RPT-F, -485F	Repeater Fiber
RPT-FW	Repeater Fiber/Wire
SCS-8	Smoke Control Station
SCE-8	Smoke Control Expander
SCS-8L	Smoke Control Lamp Driver Station
SCE-8L	Smoke Control Expander Lamp
LCD-80, -160	Annunciators
LCD-80TM	Annunciator Terminal Module LCD
XLS-FDU-80	Remote Annunciator
FFT-7, -7S	Fire Fighter's Telephone
FHS	Fireman's Handset
FPJ	Fireman's Phone Jack
AMG-E	Audio Message Generator
AA-30, -100, -120	Amplifiers
XLS-DVC	Digital Voice Command
XLS-DVC-EM	Digital Voice Command Extended Memory Module
XLS-DAA-5025, -5070	Digital Audio Amplifiers
XLS-ADDR-B4, -C4, -D4	Door Assemblies

CMIC-1	Microphone Assembly
UDACT	Universal DACT
CRT-2	Display Terminal
UZC-256	Universal Zone Coder
TELH-1	Telephone Assembly
FCPS-24S6, -24S8	Field Charger/Power Supply
XPIQ	Transponder Quad Intelligent Audio
XPM-8L	Transponder Monitor Modules
XLS-PRN-6	Printer
ACT-1, -2	Audio Coupling Transformer
RM-1, RM-1SA	Remote Microphone
S464G1007	Addressable Manual Pull Station
NBG-12LRA	Agent Releasing Abort Station
DPI-232	Panel Interface
RKS-S	Remote Security Key Switch

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label

APPROVAL: Listed as fire alarm control units suitable for use in high-rise applications when used in conjunction with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 Seconds.

XLF: 7170-0028:244

05-29-2007 jw

Date Issued: **JUNE 18, 2008**   *Listing Expires **June 30, 2009***

Authorized By: **BEN HO**, *Chief*
Fire Engineering Division